

CERTIFICATE of Conformity



Certificate No.: MK 69243434 0001

Test Report No.: 28216635 001

Certificate Holder: FRONIUS International GmbH
Günter Fronius Straße 1
4600 Thalheim bei Wels
Austria

Manufacturer: FRONIUS International GmbH
Günter Fronius Straße 1
4600 Thalheim bei Wels
Austria

Product: Photovoltaic (PV) Grid-tied inverter

Identification: Type designation: Fronius Galvo Family
a, Fronius Galvo 3.1-1
b, Fronius Galvo 3.0-1
c, Fronius Galvo 2.5-1
d, Fronius Galvo 2.0-1
e, Fronius Galvo 1.5-1
Max. DC input voltage(V): a, b, c:550; d, e:420
Operating DC input voltage(V): a, b, c:165-440;
d, e: 120-335
Max. DC input current(A): a)20,2; b)19,5; c)16,2;
d)17,8; e)13,3
Nominal AC output power(W): a)3100; b)3000; c)2500;
d)2000; e)1500
Max AC output current (A): a) 13,5; b) 13; c)10,9;
d) 8,7; e) 6,5
Nominal voltage: 230 V; Phase:1
Trademark: Fronius

Tested according to: EN 61000-6-3:2007+A1
EN 61000-3-2:2006+A1+A2
EN 61000-3-3:2008
EN 61000-6-2:2005

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2012.12.17



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu

IT_07-D-Pe_4_0