

# OVERSIZING FRONIUS SYMO GEN24

## Fronius International GmbH

Hereby confirms that the inverters

- / **Fronius Symo GEN24 3.0(Plus)**
- / **Fronius Symo GEN24 6.0(Plus)**
- / **Fronius Symo GEN24 4.0(Plus)**
- / **Fronius Symo GEN24 8.0(Plus)**
- / **Fronius Symo GEN24 5.0(Plus)**
- / **Fronius Symo GEN24 10.0(Plus)**

can be oversized above the rated nameplate capacity without voiding the manufacturer's warranty, always provided that the following conditions are adhered to.

- / The string and array (PV generator) configuration do not exceed the sizing limits of the inverter stated in the official datasheets and in this document ( $I_{sc\_max}$ ,  $P_{pv\_max}$ ,  $U_{dc\_max}$ ). This includes but it is not limited to conditions, like low temperatures, high irradiances, bifacial gain, etc. Exceeding any of these limits can destroy the inverter or even cause harm or injury.

INPUT DATA	SYMO GEN24 3.0 (PLUS)	SYMO GEN24 4.0 (PLUS)	SYMO GEN24 5.0 (PLUS)	SYMO GEN24 6.0 (PLUS)	SYMO GEN24 8.0 (PLUS)	SYMO GEN24 10.0 (PLUS)
DC input voltage range ( $U_{dc\ min} - U_{dc\ max}$ )	80 - 1 000 V ( $U_{oc\ max}$ of the PV array $\leq$ 1 000 V)					
Usable MPP input current (MPPT1/MPPT2/total) ( $I_{dc\_max}$ )	12.5 / 12.5 / 25 A	12.5 / 12.5 / 25 A	12.5 / 12.5 / 25 A	25 / 12.5 / 37.5 A	25 / 12.5 / 37.5 A	25 / 12.5 / 37.5 A
Max. PV generator short circuit current (MPPT1/MPPT2/total) ( $I_{sc\_max}$ )	20 / 20 / 40 A	20 / 20 / 40 A	20 / 20 / 40 A	40 / 20 / 60 A	40 / 20 / 60 A	40 / 20 / 60 A
Max. usable DC power (MPPT1/MPPT2/total) ( $P_{dc\_max}$ )	3.15 / 3.15 / 3.15 kW	4.18 / 4.18 / 4.18 kW	5.2 / 5.2 / 5.2 kW	6.22 / 6 / 6.22 kW	8.26 / 6 / 8.26 kW	10.3 / 6 / 10.3 kW
Max. PV generator power (MPPT1/MPPT2/total) ( $P_{pv\_max}$ )	4.5 / 4.5 / 4.5 kWpeak	6 / 6 / 6 kWpeak	6.5 / 6.5 / 7.5 kWpeak	7.5 / 6.5 / 9 kWpeak	10 / 7 / 12 kWpeak	12.5 / 7.5 / 15 kWpeak
reduced DC input voltage range ( $U_{dc\ min} - U_{dc\ max}$ )	80 - 850 V ( $U_{oc\ max}$ of the PV array $\leq$ 850 V)					
Max. PV generator power @ reduced DC input voltage range *** (MPPT1/MPPT2/total) ( $P_{pv\_max}$ )	4.5 / 4.5 / 6 kWpeak	6 / 6 / 8 kWpeak	6.5 / 6.5 / 10 kWpeak	7.5 / 6.5 / 12 kWpeak	10 / 7 / 15 kWpeak	12.5 / 7.5 / 15 kWpeak

\*\*\*Note - the oversizing values in the table vary depending on the PV array max. voltage  $U_{oc\_max}$ .

- /  $I_{sc\_pv}$  according to IEC 60364-7-712, NEC 2020, AS/NZS 5033:2021 is defined as:  $I_{sc\_pv} \geq I_{sc\_max} = I_{sc}(STC) \times 1.25$  For more detailed information, please see the technical datasheets.


\*\*\*This document does not apply for Australia and New Zealand.

## Fronius International GmbH

Business Unit Solar Energy

Froniusplatz 1

4600 Wels



Philipp Rechberger

Head of System Technology